



Format No P130/MT/01

Rev. No.00

TEST REPORT

TEST REPORT ISSUED BY: **VASAI LAB (TEST)**

TEST REPORT NO.

ULR NO.

TEST REPORT & ISSUE DATE:

DISCIPLINE : MECHANICAL TEST

CUSTOMER NAME & ADDRESS:

M/s. Sai India Gypsum Products Pvt. Ltd.

W. No. 03, Survey No. 32/5, Kundevahal, Panvel, Raigad
Navi Mumbai

QUANTITY:

DATE OF RECEIPT:

CUSTOMER REF. NO & DATE:

CONDITION OF SAMPLE ON RECEIPT:

(*)SOURCE OF SAMPLE:

TEST METHOD:

SAMPLE TESTED BY/AT: **VASAI LAB (TEST)**

TRL-40647-TR-900679

TC571326000019794F

22/07/2026

GROUP NAME : BUILDING MATERIALS

PROJECT SITE ADDRESS:

Montecarlo Limited

G3, Building Project, Girgaon Metro Station, Dr B.J.Marg
Mumbai

25 kg

29/06/2026

Letter Date-29-06-2026

Ok

SIG-MR-25 Gypsum Powder

IS 2542 : Part-1 (Sec-1,3,4,5,6,7,8,9,12) : 2023, Reference Standard IS 2547

Part -1 : 1976 RA 2022 Amd-3, IS 2547 Part -2 : 1976 RA 2022 Amd-1

PHYSICAL TEST RESULT OF GYPSUM PLASTER

(*)CLASS & TYPE OF PLASTER : IS 2547 Part-1 & Plaster of Paris- Type A (short time setting)

PERIOD OF TEST : 16/07/2026 TO 17/07/2026

(*)SAMPLE ID: SIG-MR-25 Gypsum Powder

Sr No	Type of Test	Test Method	Test Result	Requirement As Per IS 2547 (Part-I)			
				Plaster of Paris- Type A (short time setting)	Plaster of Paris- Type B (long time setting)	Anhydrous Gypsum Plaster	Keene's Plaster
1	Normal Consistency, %	IS 2542 (Part-1/Sec-1)	67	--	--	--	--
2	Setting Time (Neat Plaster), Minutes	IS 2542 (Part-1/Sec-3)	15	10-30	60-180	20-360	20-360
3	Soundness	IS 2542 (Part-1/Sec-6)	No sign of Disintegration, Popping or Pitting.	Set plaster pats shall not show any sign of disintegration, popping or pitting			
4	Expansion, %	IS 2542 (Part-1/Sec-9)	0.10	--	Max. 0.2 at 24 h !	--	Max 0.5 at 96 h
5	Mass of Coarse Particles (Residue on 150µ), %	IS 2542 (Part-1/Sec-8)	1.65	Max. 5	Max. 5 # Max. 1.0 ##	Max. 2	Max. 2

Remarks:

(*)Mark Information furnished by the customer and can affect the validity of test results.

(#) Applicable to under coat plaster only

(##) Applicable to final coat plasters

(!) Applicable for board finish Plaster only

Test Witnessed: Mr. Ankit Goswami & Mr. Amit.



TEST REPORT NO. : TRL-40647-TR-900679

ULR NO. : TC571326000019794F

DISCIPLINE : MECHANICAL TEST

GROUP NAME : BUILDING MATERIALS

NOTE:

- Sample/s was/were not drawn by laboratory.
- The Reported result/s is/are valid only to the sample submitted to the laboratory.
- No part of the report, except in full, shall be reproduced without written consent of the laboratory.

-- The authenticity of this report can be verified by scanning the Report QR code. Also, check that the report should be downloaded with the URL: globallab.co.in.

*****End of Report*****



Mahemood ahmed
Authorized Signatory



SCAN HERE TO KNOW NABL SCOPE



SCAN HERE TO KNOW YOUR REPORT

